

**New Jersey Turnpike Authority
Engineering Department**

**Request for Expressions of Interest
Order for Professional Services No. P4044
Replacement of Pleasant Plains and Avalon Sub-Station and Site Improvements**

Response to Inquiries

Inquiry: Will the new buildings at Pleasant Plains and Avalon be commissioned by a third-party commissioning agent throughout the design and construction process?

Response: Yes, a third-party commissioning agent (provided by the NJTA) will be utilized during the design and construction of the substations. The designer is expected to participate in the commissioning process. Contract specifications documents shall include a commissioning section for HVAC equipment, generators, and other systems identified by the Authority during the design process.